



Leino Park Water District
 52 Old Oak Ave., Westminister, MA 01473
 lpwd@comcast.net

CONSUMER CONFIDENCE REPORT (CCR) 2007

As you know, Leino Park's water is supplied by the Westminister Water Department, which buys its water from the City of Fitchburg. In addition to the water quality testing done by Fitchburg and Westminister, Leino Park is required to monitor for lead, copper, and disinfection contaminants within its distribution system. The results of our tests are shown below. For an explanation of the terms in these tables, please refer to the attached 2007 Drinking Water Quality Report from Westminister.

WATER QUALITY DATA TABLES

Lead and Copper	Date Collected	90 th Percentile*	Action Level (AL)	MCLG	# of Sites Sampled	# of Sites above AL	Exceeds AL (Y/N)	Possible Sources
Lead (ppb)	6/12/07 8/14/07	0.006 0.007	.015	0	10	0	N	Corrosion of household plumbing
Copper (ppm)	6/12/07 8/14/07	0.15 0.02	1.3	1.3	10	0	N	Corrosion of household plumbing

* Lead and copper compliance is based on the 90th percentile value, which is the highest level found in 9 out of every 10 homes sampled. The 90th percentile value is then compared to the action level.

Disinfection Contaminants	Date(s) Collected	Highest Running Annual Average	Range Detected	MCL or MRDL	MCLG or MRDLG	Violation (Y/N)	Possible Sources
Haloacetic Acids (HAA5s) (ppb)	8/14/07 11/13/07	17.4	17.2-17.6	60	--	N	Byproduct of drinking water chlorination
Total Trihalomethanes (TTHMs) (ppb)	Quarterly	95.6	81.6-122.4	80	--	Y	Byproduct of drinking water chlorination
Chlorine (ppm)	2 Times a Month	0.33	0.09 - 0.56	4	4	N	Water additive used to control microbes

2007 Compliance: Leino Park continues to have a problem with trihalomethanes in our water. This year we received four notices of noncompliance from the Massachusetts DEP for trihalomethane MCL violations and provided public notice to you each time. The Leino Park Water District, Holmes Park Water District, Westminister Water Department and the City of Fitchburg are working together to develop a strategy to address this problem.

Our water district consumed 1,836,930 gallons of water in 2007. Please conserve water inside and outside your homes. Please water lawns only when needed, ideally early in the morning or after the sun goes down.

Our Annual Meeting will be held on June 28, 2008 at Bob Brown's, 46 Old Oak Ave. @10:30 AM. Residents are invited to attend. For questions and comments, or for additional copies of this report, contact David Crumbley @ 978-874-2569 or lpwd@comcast.net. You can also contact any of the following Commissioners:

Robert Brown @ 978-874-0408 Richard Plante @ 978-874-0474 Donald Williams @ 978-874-1908