



Leino Park Water District
 52 Old Oak Ave., Westminster, MA 01473
www.leinopark.org lpwd@comcast.net

CONSUMER CONFIDENCE REPORT (CCR) 2009

As you know, Leino Park's water is supplied by the Westminster Water Department, which buys its water from the City of Fitchburg. In addition to the water quality testing done by Fitchburg and Westminster, Leino Park is required to monitor for lead, copper, and disinfection contaminants within its distribution system. The results of our tests are shown below. For an explanation of the terms in these tables, please refer to the attached 2009 Drinking Water Quality Report from Westminster.

WATER QUALITY DATA TABLES

Disinfection Contaminants	Date(s) Collected	Highest Running Annual Average	Range Detected	MCL or MRDL	MCLG or MRDLG	Violation (Y/N)	Possible Sources
Haloacetic Acids (HAA5s) (ppb)	Quarterly	46	28 - 46	60	--	N	Byproduct of drinking water chlorination
Total Trihalomethanes (TTHMs) (ppb)	Quarterly	82	45 - 81	80	--	Y	Byproduct of drinking water chlorination
Chlorine (ppm)	2 Times a Month	0.4	0.04 - 0.82	4	4	N	Water additive used to control microbes

2009 Compliance: Leino Park continues to have a problem with trihalomethanes in our water. This year we received two notices of noncompliance from the Massachusetts DEP for trihalomethane MCL violations and provided public notice to you each time. The Leino Park Water District, Holmes Park Water District, Westminster Water Department and the City of Fitchburg are working together to develop a strategy to address this problem.

Our water district consumed 1,897,099 gallons of water in 2009. Please conserve water inside and outside your homes. Please water lawns only when needed, ideally early in the morning or after the sun goes down.

Leino Park Directors meet the first Wednesday of every month.

Our Annual Meeting will be held on Saturday, June 26, 2010 at the Beach area opposite 36 Old Oak Ave. @10:00 AM. Residents are invited to attend. For questions and comments, or for additional copies of this report, contact David Crumbley @ 978-874-2569 or lpwd@comcast.net or our website www.leinopark.org. You can also contact any of the following Commissioners:

Robert Brown @ 978-874-0408 Richard Plante @ 978-874-0474 Donald Williams @ 978-874-1908