



Leino Park Water District
 52 Old Oak Ave., Westminster, MA 01473
www.LeinoPark.org lpwd@LeinoPark.org

CONSUMER CONFIDENCE REPORT (CCR) 2010

As you know, Leino Park's water is supplied by the Westminster Water Department, which buys its water from the City of Fitchburg. In addition to the water quality testing done by Fitchburg and Westminster, Leino Park is required to monitor for bacteria, lead, copper, chlorine, and disinfection contaminants within its distribution system. The water quality information presented in the tables below is from the most recent round of testing in accordance with regulations. Only the detected contaminants are shown. For an explanation of the terms in these tables, please refer to the attached 2010 Drinking Water Quality Report from Westminster.

WATER QUALITY DATA TABLES

Lead and Copper	Date Collected	90 th Percentile *	Action Level (AL)	MCLG	# of Sites Sampled	# of Sites above AL	Exceeds AL (Y/N)	Possible Sources
Lead (ppb)	8/11/08	0.008	.015	0	10	0	N	Corrosion of household plumbing
Copper (ppm)	8/11/08	0.15	1.3	1.3	10	0	N	Corrosion of household plumbing

* Lead and copper compliance is based on the 90th percentile value, which is the highest level found in 9 out of every 10 homes sampled. The 90th percentile value is then compared to the action level.

Disinfectants and Disinfection Contaminants	Date(s) Collected	Highest Running Annual Average	Range Detected	MCL or MRDL	MCLG or MRDLG	Violation (Y/N)	Possible Sources
Haloacetic Acids (HAA5s) (ppb)	Quarterly	42	12-55	60	--	N	Byproduct of drinking water chlorination
Total Trihalomethanes (TTHMs) (ppb)	Quarterly	81	50-97	80	--	Y*	Byproduct of drinking water chlorination
Total Chlorine (ppm)	2 Times a Month	0.58	0.02-1.02	4	4	N	Water additive used to control microbes

*Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems their liver, kidneys, or central nervous systems, and may increase the risk of getting cancer.

Leino Park Water District
CONSUMER CONFIDENCE REPORT (CCR) 2010

2010 Compliance: Leino Park continues to have a problem with trihalomethanes in our water. This year we received one notice of noncompliance from the Massachusetts DEP for trihalomethane MCL violations and provided public notice to you. The Leino Park Water District, Westminster Water Department and the City of Fitchburg are working together to develop a strategy to address this problem.

Our water district consumed 2,073,538 gallons of water in 2010. Please conserve water inside and outside your homes. Please water lawns only when needed, ideally early in the morning or after the sun goes down.

The Leino Park Water District Board of Commissioners meet on the first Wednesday of every month, 7:00 PM at the Miller residence, 15 Old Oak Ave. The Public is invited.

Our Annual Meeting will be held on Saturday June 18, 2011 at Bob Brown's house, 46 Old Oak Ave. at 10:00 AM. Residents are encouraged to attend. For questions and comments, or for additional copies of this report, contact David Crumbley at 978-874-2569 or Dave@LeinoPark.org or visit our website at www.LeinoPark.org. You may also contact any of the following Commissioners:

Robert Brown @ 978-874-0408 Richard Plante @ 978-874-0474 Donald Williams @ 978-874-1908